


TECHLUME

A U S T R A L I A

Product Overview

Product Name / Code: CREST 24W Low Glare Panel Light - LC7215
Description: 600x600mm, 4000K, Non-Dim
Manufacturer: Decrolux Lighting Pty Ltd



Laboratory and Equipment

System Name: LabSpion Goniometer
Sensor Name / Model: LabSensor Model2 / Freedom VIS (Custom Viso)
Calibration Date: 7/12/2022
Manufacturer: Viso Systems, Denmark

Measurement Details

Test Date and Time: 11/07/2023 7:43:22 PM
Measurement Method: Far Field, Type C Horizontal
Measurement Distance: 446.4 cm
Ambient Temperature: 25 °C ± 1 °C



Photometric Measurements

Total Luminous Flux	Luminous Efficacy	Luminous Intensity
3094 lm	127 Lumen/watt	1590 cd


Correlated Colour Temperature, Target	Correlated Colour Temperature, Measured	Colour Rendering Index (CRI)
4000 K	4024 K	Ra 82.1

Electrical Measurements

Input Voltage	Input Current	Input Power	Input Voltage Frequency
240 VAC	0.111 A	24.4 W	60 Hz

Power Factor	Stabilisation Time	Stabilisation Variation	Hours Operated Prior to Test
0.92	Lamp stabilized in 30 min 1 sec	-0.2%	0 hours

Polar Diagram



Beam Angle 80.7°

Colour Rendering Index Per Reference Colour

