



TECHLUME

A U S T R A L I A

LM-79 Test Report

Testing Method:	IES Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products
Relevant Standards:	IES LM-79-08
Test Date and Time:	11/12/2023 10:53:25 AM
Test Location:	Techlume Australia - East Goderich Street Deloraine, TAS 7304
Operator:	JE
Measurement Number:	VFR-231211-0273-MS
Measurement Method:	Far Field, Type C Horizontal
Measurement Distance:	450.7 cm

Equipment Used

System Name:	LabSpion Goniometer
Sensor Name / Model:	Viso LabSensor Model2 / Freedom VIS (Custom Viso)
Spectrometer Range:	360 nm – 830 nm
Calibration Date:	7/12/2022
Flicker Meter Type:	Viso Systems LabFlicker
Manufacturer:	Viso Systems, Denmark

Test Conditions

Ambient Temperature:	25 °C ± 1 °C
----------------------	--------------

Remarks

The results stated in this report represent the tested sample only. All photometric and colourimetric data has been measured in compliance with IES LM-79-08 standards.



Product Overview

Product Description:


RHYNE 120W Floodlight, 5700K, 120°, IP66, Black, Non-Dim w. Plug & Lead

Item Number:

LC2353

Manufacturer:

Decrolux Lighting Pty Ltd



Photometric Measurements

Total Luminous Flux	Luminous Efficacy	Luminous Intensity
15401 lm	136 Lumen/watt	7391 cd

Correlated Colour Temperature, Target	Correlated Colour Temperature, Measured	Colour Rendering Index (CRI)
5700 K	5802 K	Ra 83.8


Electrical Measurements

Input Voltage	Input Current	Input Power	Input Voltage Frequency
240 VAC	0.482 A	112.9 W	60 Hz


Power Factor	Stabilisation Time	Stabilisation Variation	Hours Operated Prior to Test
0.97	Lamp stabilized in 59 min 44 sec	-4.7%	0 hours



Spectral Power Distribution (SPD)



Input Power Curve




Flicker Details


Flicker Sample Rate	Flicker Percentage	Flicker Frequency	Flicker Index
n/a sample/s	n/a%	n/a Hz	n/a

Flicker SVM Value	Flicker PstLM Value	Measurement Time (PstLM)	Measurement Time (all other indices)
n/a	n/a	180 s	1.2 s

IEEE 1789 Frequency/Modulation Plot



Angular Distribution – 0° / 90° Plane



Main Values

Total Lumen Output	15401 lm
Lumen Up%	0.16%
Lumen Down%	99.84%
Peak Intensity	7391 cd
Beam Angle (90%)	94.4°

Cut-off Angle

Average 2.5%	151.3°
--------------	--------

Field Angle


Average 10%	132.9°
-------------	--------

Intensity Ratio

In 120° Cone	92.2%
In 90° Cone	68.3%

C000-C180

C090-C270



Beam intensities from 1 – 20m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3.3	6.6	9.8	13.1	16.4	19.7	23	26.2	29.5	32.8	36.1	39.4	42.7	45.9	49.2	52.5	55.8	59.1	62.3	65.6	ft
7384	1846	820	461	295	205	151	115	91	74	61	51	44	38	33	29	26	23	20	18	lux
686	171.	76.2	42.9	27.4	19.1	14	10.7	8.5	6.9	5.7	4.8	4.1	3.5	3	2.7	2.4	2.1	1.9	1.7	fc




Colour Details

Colour Rendering Index (CRI)	Colour Rendering Index R9 Value	Colour Rendering TM30-18
Ra 83.8	R9 = 10.0	R _f 82.8, R _g 93.1

Colour Quality Scale	Correlated Colour Temperature, Target	Correlated Colour Temperature, Measured
CQS = 80.6	CCT = 5700 K	CCT = 5802 K


MacAdam Steps	Colour Coordinates CIE 1931	Colour Deviation from BBL
SDCM = 4.5	(x;y) = (0.328;0.337)	Duv = 0.0003

Colour Rendering Index per reference colour (CIE 1995)




R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
82.5	90.8	93.8	81.4	82.0	84.9	87.0	68.4	10.0	76.5	80.6	56.5	85.5	97.1	77.0

TM30-18 R_f-values per hue bin




C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
75.1	84.2	81.8	87.4	87.4	94.1	88.7	83.4	81.3	72.5	75.0	91.0	86.3	83.4	70.8	85.1


CIE 1931



CIE 1931 – Zoomed




Iso-intensity Diagram (Iso-Candela)



90 %	6649.8 cd
80 %	5910.9 cd
70 %	5172.0 cd
60 %	4433.2 cd
50 %	3694.3 cd
40 %	2955.5 cd
30 %	2216.6 cd
20 %	1477.7 cd
10 %	738.9 cd

Peak intensity: 7388.6 cd
Number of c-planes: 16

Iso-illuminance Diagram (Iso-lux)



50.0 %	410.3 lx
30.0 %	246.2 lx
10.0 %	82.1 lx
5.0 %	41.0 lx
3.0 %	24.6 lx

Peak illuminance: 820.6 lx
Mounting height: 3.0 m
Number of c-planes: 16



Light Planning – UGR table

Uncorrected, comprehensive UGR table according to 117-1995

Reflectances		70	70	50	50	30	70	70	50	50	30
ρ Ceiling		70	70	50	50	30	70	70	50	50	30
ρ Walls		50	30	50	30	30	50	30	50	30	30
ρ Floor		20	20	20	20	20	20	20	20	20	20
Room size		Viewed Crosswise					Viewed Endwise				
H = mounting height above eye level		(Viewing direction orthogonal to lamp length axis)					(Viewing direction parallel to lamp length axis)				
X	Y										
2H	2H	25.9	26.9	26.1	27.2	27.4	25.7	26.7	25.9	27.0	27.2
	3H	26.0	27.0	26.4	27.3	27.5	25.8	26.9	26.2	27.1	27.3
	4H	26.0	27.0	26.4	27.3	27.5	25.8	26.8	26.2	27.1	27.3
	6H	26.0	26.9	26.3	27.1	27.5	25.8	26.7	26.1	27.0	27.3
	8H	25.9	26.8	26.3	27.1	27.5	25.8	26.6	26.1	26.9	27.3
	12H	25.9	26.7	26.3	27.1	27.5	25.7	26.5	26.1	26.9	27.3
4H	2H	25.9	26.9	26.3	27.2	27.5	25.8	26.8	26.2	27.1	27.3
	3H	26.2	27.0	26.6	27.4	27.8	26.1	26.9	26.4	27.2	27.7
	4H	26.2	26.9	26.6	27.3	27.9	26.0	26.8	26.4	27.2	27.7
	6H	26.1	26.9	26.6	27.2	27.6	26.0	26.7	26.5	27.0	27.4
	8H	26.1	26.8	26.6	27.1	27.5	25.9	26.6	26.4	26.9	27.3
	12H	26.0	26.6	26.5	27.0	27.5	25.9	26.4	26.4	26.8	27.3
8H	4H	26.1	26.8	26.6	27.1	27.5	25.9	26.6	26.4	27.0	27.3
	6H	26.1	26.6	26.6	27.0	27.6	25.9	26.4	26.4	26.9	27.4
	8H	26.1	26.5	26.6	27.0	27.6	25.9	26.3	26.4	26.8	27.5
	12H	26.0	26.4	26.6	26.9	27.5	25.9	26.2	26.4	26.7	27.3
12H	4H	26.0	26.6	26.5	27.0	27.5	25.9	26.4	26.4	26.8	27.3
	6H	26.1	26.5	26.6	27.0	27.6	25.9	26.3	26.4	26.8	27.5
	8H	26.0	26.4	26.6	26.9	27.5	25.9	26.2	26.5	26.7	27.3
Variations with the observer position for the luminaire spacings, S:											
S = 1.0H		0.3 / -0.6					0.4 / -0.7				
S = 1.5H		1.4 / -2.7					1.3 / -2.8				
S = 2.0H		2.8 / -5.1					2.7 / -5.3				

NOTE: An asymmetry correction has been applied to the beam distribution of this measurement in order to accurately calculate UGR.

Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR		(RCR: Room Cavity Ratio)										Room Values are expressed as percentage of Lumen delivered to the task surface						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	111	107	104	101	108	105	102	99	101	98	96	97	95	93	94	92	90	88
2	103	96	90	86	100	94	89	85	91	86	83	88	84	81	85	82	79	77
3	95	86	79	73	93	84	78	73	82	76	72	79	74	70	76	73	69	67
4	88	77	70	64	86	76	69	63	74	67	63	71	66	62	69	65	61	59
5	81	70	62	56	79	69	61	56	67	60	55	65	59	54	63	58	54	52
6	75	63	55	50	74	62	55	49	61	54	49	59	53	49	58	52	48	46
7	70	58	50	44	69	57	49	44	56	49	44	54	48	43	53	47	43	41
8	66	53	45	40	64	52	45	40	51	44	39	50	44	39	49	43	39	37
9	61	49	41	36	60	48	41	36	47	41	36	46	40	36	45	40	35	34
10	58	45	38	33	56	45	38	33	44	37	33	43	37	33	42	36	32	31

